

LOCATION 3/4 1/2 S. Columbia St.

CITY CASTONIA

BETWEEN Second St.

STREET & Third St.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>160'</u>	<u>2-27-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>0'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>160'</u>			

ENTERS: 3/4 BRANCHED INTO: 3/4 1/2

TAP SIZE: 3/4 straight P. Tee PRESSURE 60 P.S.I. INCHES W.C. LOCATION 375' N of 3rd St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

Service MAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH: 2 Ft. 0 In. LOCATION 102' E of 1st S. Columbia St.

"A" P/S READING PLASTIC TOTAL ANODES 1\* 17\* L.R. # 076998

REMARKS: 3/4 split PLASTIC Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY