

LOCATION 322 + 322 1/2 S. Columbia

CITY Gastonia

BETWEEN 3rd

STREET &amp; 2nd.

STREET

	SIZE	TYPE	322 LENGTH 322 1/2		INSTALLED	322 RETIRED 322 1/2		RENEWED
MAIN TO BLDG.	3/4	P	221'	28'	5-3-95	5-3-95		5-3-95
MAIN TO PROP. LINE	3/4	P	40'			26'	218'	
PROP. LINE TO BLDG.	3/4	P	181'			3/4" CW	3/4" CW	

ENTERS: 322

BRANCHED INTO: 322 1/2

1965 1964

TAP SIZE: 1/2

PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C.

LOCATION 17' W OF

S. Columbia

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M Parker

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1994


DEPTH: 3 Ft. 0 In. LOCATION 208' N. OF 3rd

"A" P/S READING P

TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_

L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P-riser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY