

LOCATION 419 S. Columbia St CITY Gastonia
BETWEEN E. Maple St STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>30'</u>	<u>7-18-83</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>15'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>15'</u>			

ENTERS 419 BRANCHED INTO 417
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 60' W. of center
S. Columbia St

PRESSURE TEST @ 100 PSI FOR 4 HRS BY S.H.

MAIN SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1988
DEPTH 2 FT 0 IN LOCATION 65' S. of center of E. Maple St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 193647

REMARKS

