

LOCATION 425 S. Columbia St. CITY Columbia
BETWEEN Maple STREET & 5th STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>I</u>	<u>1'</u>	<u>8-7-93</u>	<u>Tied over 43' OP</u>	
MAIN TO PROP. LINE					<u>EXT 3/4' to EXT 3/4'</u>	
PROP. LINE TO BLDG.					<u>Plastic Service</u>	

ENTERS: 423 BRANCHED INTO: 425
TAP SIZE: 3/4" S.W. PRESSURE 60 P.S.I. INCHES W.C. LOCATION 32' W of Columbia
212' S of Maple


PRESSURE TEST: @ 100 psi For 4 Hrs. By EP

MAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 1 Ft. 0 In. LOCATION

"A" P/S READING 1.3 TOTAL ANODES 1* 1 17* L.R. #

REMARKS: Tracer wire tied at At Tee



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R/S</u>	<u>1.3</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY