

LOCATION 428 S. Columbia St. CITY GASTON, N.C.  
BETWEEN 5th STREET & Maple STREET

	SIZE	TYPE	LENGTH	INSTALLED	<del>RETIRED</del>	<del>RENEWED</del>
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>21'</u>	<u>8-7-93</u>	<u>Tied over</u>	<u>24' of EXT</u>
MAIN TO PROP. LINE					<u>3/4" G.P. Ser. to EXT 2"</u>	
PROP. LINE TO BLDG.					<u>Plastic Man</u>	

ENTERS: 428 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 12' W of Col of Columb.  
308' S of Col of Maple

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP


MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION \_\_\_\_\_

"A" P/S READING 1.2 TOTAL ANODES 1 \* 1 / 17 \* 0 L.R. # \_\_\_\_\_

REMARKS:

Timer wire tied off at main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>Riser</u>	<u>1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY