

LOCATION 439 S Columbia St CITY GASTONIA
BETWEEN MAPLE STREET & 5th AVE STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>CW Plastic</u>	<u>60' 5"</u>	<u>tie over 8/6/93</u>		
MAIN TO PROP. LINE		<u>TOTAL</u>	<u>65'</u>			
PROP. LINE TO BLDG.						

ENTERS: 439 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION North side of 439

PRESSURE TEST: @ 100 psi For 14 Hrs. By DS
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1992
DEPTH: 3 Ft. 0 In. LOCATION West side of S Columbia

"A" P/S READING .60 TOTAL ANODES 1* 1 17* 0 L.R. #

REMARKS: Note: tied over 60' of 3/4" CW service to new main with 5' of 3/4" Plastic PIP.
The .60^{PS} Reading taken Before Anode Installed
The .95^{PS} Reading taken After Anode Installed



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>.95</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY