

LOCATION 440 S Columbia St CITY GASTONIA  
BETWEEN 5th Ave STREET & Maple STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	new Plastic	45'	tied over 8/6/93		
MAIN TO PROP. LINE			47'			
PROP. LINE TO BLDG.		TOTAL	92'			

ENTERS: 440 BRANCHED INTO:  
TAP SIZE: 1/2" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION NORTH side of 440

PRESSURE TEST: @ 100 psi For 14 Hrs. By DK  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1992  
DEPTH: 3 Ft. 0 In. LOCATION West side of S Columbia St

"A" P/S READING .60 TOTAL ANODES 1# L 17# 0 L.R. # \_\_\_\_\_

REMARKS: Tied over 45' of Ex 3/4" Csw Service with  
47' of 3/4" Plastic P180  
The 1.40 PS Reading taken After Anode Installed  
The .60 PS Reading taken Before Anode Installed



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	1.40
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY