

LOCATION 107 Colvard Dr. CITY GASTONIA
BETWEEN Beaty Rd. STREET & Dead End STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>120'</u>	<u>1-22-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>37'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>83'</u>			

ENTERS: 107 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 600 P.S.I. _____ INCHES W.C. LOCATION 282' W of Caf Beaty Rd.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1987
DEPTH: 3 Ft. 0 In. LOCATION 14' N of Caf Colvard Dr.

"A" P/S READING PLASTIC W/A TOTAL ANODES 1# 0 17# 0 L.R. # 021666

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser PLASTIC
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY