

LOCATION 108 Colvard Dr. CITY GASTON, NC

BETWEEN Becky Rd. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>77'</u>	<u>10-2-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>67'</u>			

ENTERS: 108 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 333' NE of center of

Becky Rd


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hults

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992

DEPTH: 3 FT. 0 IN. LOCATION 15' NE. of center of Colvard Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 668995

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		