

LOCATION 106 + 100 Congress Ct CITY GASTONIA  
BETWEEN Davenport STREET & Ruby Ave STREET

	SIZE	TYPE &	106 LENGTH 100	INSTALLED	100 RETIRED 106	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>186'</u>	<u>51'</u>	<u>125' of 3/4" BARE</u>	<u>S- 13-95</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>130'</u>	<u>10'</u>	<u>60' of 1" BARE</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>56</u>	<u>41</u>		

ENTERS: 106 Congress Ct BRANCHED INTO: 100 Congress Ct

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Elmore

MAIN-SIZE 8" C.I.     BARE STEEL     COATED STEEL ✓ PLASTIC     YEAR INSTALLED 1994

DEPTH: 3 Ft. 6 In. LOCATION

"A" P/S READING .9 TOTAL ANODES 1\*     17\*     L.R. #    

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY