

LOCATION 1402 CONGRESS St. CITY GA STONIA
BETWEEN CONGRESS STREET & CONGRESS STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/W</u>	<u>5</u>	<u>9-13-96</u>		
MAIN TO PROP. LINE	<u>1</u>	<u>11</u>				
PROP. LINE TO BLDG.	<u>1</u>	<u>1</u>				

ENTERS: 1402 BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 20' w. of C of Congress

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP
MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1962
DEPTH: 1 FT. 0 IN. LOCATION _____

"A" P/S READING 1.40 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>1.40</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY