

LOCATION 1409 Congress St CITY GASTONIA
BETWEEN Fosteria DR. STREET & Marquette St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>71'</u>	<u>10-17-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>25'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>46'</u>			

ENTERS: 1409 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 21' E. of center of

Fosteria DR


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY S. GERTSCH

MAIN-SIZE 3" C.I. _____ BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED 1959

DEPTH: 2 FT. 0 IN. LOCATION 12' N. of center of Congress St

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 L.R. # 580124

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY