

LOCATION 1411 Congress St CITY GASTONIA
BETWEEN 2nd STREET & Ruby STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>1'</u>		<u>Tied over</u>	<u>8'3" O.A. 1994</u>
MAIN TO PROP. LINE					<u>3/4" CW Service to Ext</u>	
PROP. LINE TO BLDG.					<u>By Plastic in #7</u>	<u>1505 S. Marietta</u>

ENTERS: 1505 S. Marietta BRANCHED INTO: # 1411 Congress 10-20-95

TAP SIZE: 3/4 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 psi For 44 Hrs. By SP


MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1994

DEPTH: 2 Ft. 6 in. LOCATION _____

"A" P/S READING Plastic TOTAL ANODES 1* 1 17* _____ L.R. # _____

REMARKS:

TAPOR WIRE Tied off at Tee



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>P.S. 1505</u>	<u>1.4</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY