

LOCATION 1911 CONNEMARA CT CITY CASTONIA

BETWEEN Lochness DR. STREET & Cut de - SAC STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	90'	8-21-96		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	85'			

ENTERS: 1911 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI          INCHES W.C. LOCATION 129' SE of center of

Lochness Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HUFFBAGH

MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 1988

DEPTH: 3 FT. 0 IN. LOCATION 19' SW. of center of CONNEMARA CT.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 445955

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY