


LOCATION 1600 + 1612 Conrad AveCITY GastoniaBETWEEN ConradSTREET & Linwood

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	15'	7-9-94	Tied over	675' 3/4"
MAIN TO PROP. LINE					Existing C+W pipe to	
PROP. LINE TO BLDG.					Existing 4" P. Main	

ENTERS: 1600BRANCHED INTO: 1612TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION '43' N of C ofConradPRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993DEPTH: 3 Ft. In. _____ LOCATION 25' W of C of Linwood"A" P/S READING P. Plastic TOTAL ANODES 1* 1 17* - L.R. # 292850REMARKS: Wire tied of at Main

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	3 Riser	1.1
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY