

LOCATION 127 COOKS LAKE RD. CITY GASTONIA
BETWEEN BEATY RD STREET & KELTIC MEADOWS STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>105'</u>	<u>08/02/95</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>65'</u>			

ENTERS: 127 BRANCHED INTO: _____
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By SA

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 Ft. 6 In. LOCATION 283' E OF C OF BEATY RD / 14' S OF C OF COOKS LAKE RD

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # 00369212

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY