

LOCATION 150 COOKS LAKE RD CITY GASTONIA
BETWEEN Geaty Rd STREET & Keltic Meadows STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>75'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>	<u>10-19-96</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>70'</u>			

ENTERS: 150 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION


PRESSURE TEST: @ 105 PSI FOR 44 HRS. BY EP

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1986

DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING 1.15/1.36 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY