

LOCATION 1753 Country Club Rd. CITY Boston
BETWEEN Wilmon STREET & Ridge STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>Plastic</u>	<u>148'</u>	<u>9-13-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>Plastic</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>Plastic</u>	<u>108'</u>			


ENTERS 1753 BRANCHED INTO 0
TAP SIZE 3/8" PRESSURE 40 PSI INCHES W C LOCATION 102' E of C of Wilmon

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 4" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1964
DEPTH 3 FT 4 IN LOCATION 12' N of C of Country Club Rd.

"A" P/S READING 1.22 TOTAL ANODES 1# 0 17# 0 LR # 00051636

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>