

LOCATION 1838 Country Club Rd. CITY Gastonia  
BETWEEN New Hope STREET & Ridge STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>127'</u>		<u>X</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			<u>12-19-90</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>122'</u>			

ENTERS: 1838 BRANCHED INTO: 0

TAP SIZE: 1" MC PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_


PRESSURE TEST: @ 105 PSI FOR 44 HRS. BY EP

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1964

DEPTH: 3 FT. 6 IN. LOCATION \_\_\_\_\_

"A" P/S READING 1.1 TOTAL ANODES 1# 0 17# 0 L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>11.5</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY