

LOCATION 1848 County Club Rd CITY Cassonia
BETWEEN New Hope STREET & Ridge STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>115'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>		<u>8-19-96</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>105'</u>			

ENTERS: 1848 BRANCHED INTO: 0

TAP SIZE: 3/4 PRESSURE 60 P.S.I. INCHES W.C. LOCATION


PRESSURE TEST: @ 105 psi For 44 Hrs. By EP

MAIN-SIZE 4" C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1954

DEPTH: 3 Ft. 0 In. LOCATION

"A" P/S READING .6 TOTAL ANODES 1* 0 17* 1 L.R. #

REMARKS: Used Ext Miller Tee



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY