

LOCATION 2018 Country Club Rd CITY GASTONIA

BETWEEN COLLIER ST. AND WEST CLUB CIR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PL</u>	<u>122'</u>			<u>11-24-1997</u>
MAIN TO PROP. LINE	<u>3/4"</u>	<u>PL</u>	<u>40'</u>			<u>1997</u>
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>PL</u>	<u>82'</u>			<u>1997</u>

ENTERS: 2018 Country Club Rd BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 69' EAST OF CENTER

ON WEST CLUB CIR


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D. MYERS

MAIN-SIZE 2" C.I.  BARE STEEL  COATED STEEL  PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. IN. LOCATION 20' SOUTH OF CENTER ON COUNTRY CLUB RD

"A" P/S READING  TOTAL ANODES 1#  17#  L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY