

LOCATION 3416 Country Club Dr CITY Gastonia

BETWEEN Brentwood Dr. STREET & Clubview Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	180'	11-12-97		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	140'			

ENTERS: 3416 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 698' E. of center of

Brentwood Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hurtstoffer

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED

DEPTH: 3 FT. 0 IN. LOCATION 185' of center of Country Club Dr.

"A" P/S READING .9 TOTAL ANODES 1# 0 17# 0 L.R. # 756313

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY