

LOCATION 2104 Court Dr. CITY Gastonia

BETWEEN Separk Cir. STREET & N. Newhope Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.						
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: _____ BRANCHED INTO: _____

TAP SIZE: _____ PRESSURE _____ PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ _____ PSI FOR _____ HRS. BY _____

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1958

DEPTH: 3' FT. 6" IN. LOCATION Court Dr.

"A" P/S READING 2.014 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Bonded insulator tee on 3/4" C+W 1/2 service line to 2" C+W gas main. C.P. # 01872.
Reading: 1.180 before bond + 1.895 after bond was made.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY