

LOCATION 3000 Courtland Dr. CITY Gastonia

BETWEEN Andrea Ln. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>393'</u>	<u>2-7-00</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>50'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>348'</u>			

ENTERS. 3000 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES WC LOCATION 6' N. of center of Andrea Ln.


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.H.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1967

DEPTH: 8 1/2 FT 0 IN LOCATION 17' E. of center of Courtland Dr.

"A" P/S READING .6 TOTAL ANODES 1# 0 17# 1 I.R. # 65980

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	