


LOCATION	202 Cox Dr			CITY	GASTONIA		
BETWEEN	Church St		STREET @	Cedar St.		STREET	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED	
MAIN TO BLDG.	3/4"	P	66'	3-8-95			
MAIN TO PROP. LINE	3/4"	P	25'				
PROP. LINE TO BLDG.	3/4"	P	41'				
ENTERS: 202 BRANCHED INTO:							
TAP SIZE:	1/2	PRESSURE	60 P.S.I.	INCHES W.C.	LOCATION 97' W. of center of Church St		
PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S Huffstutz							
MAIN-SIZE	2"	C.I.	BARE STEEL	COATED STEEL <input checked="" type="checkbox"/>	PLASTIC	YEAR INSTALLED 1962	
DEPTH:	3 Ft.	0 In.	LOCATION 11' N. of center of Cox Dr				
"A" P/S READING	1.4	TOTAL ANODES 1# 0 17# 0			L.R. # 96015		

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY