

LOCATION 310-A Cox Rd.

CITY GASTONIA

BETWEEN

STREET &amp;

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	60'	9-1-95	Replaced	60' DAMAGED
MAIN TO PROP. LINE					3/4 Plastic	Service Pipe.
PROP. LINE TO BLDG.						

ENTERS: 310-A

BRANCHED INTO: 0

TAP SIZE:

PRESSURE

P.S.I.

INCHES W.C.

LOCATION

PRESSURE TEST: @ 100 psi

For 1/4 Hrs.

By RL

Service  
MAIN-SIZE 3/4

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED 1995

DEPTH:

Ft.

In.

LOCATION


"A" P/S READING

N/A

TOTAL ANODES 1# 17#

L.R. #

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	