

LOCATION 325 Cox Dr. CITY CASTONIA  
BETWEEN Mt Hebron Church Rd. STREET & COX Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>67'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>1'</u>			<u>8-15-96</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>66'</u>			


ENTERS: 325 BRANCHED INTO: 0  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION

PRESSURE TEST: @ 105 PSI FOR 1/4 HRS. BY CP  
MAIN SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED \_\_\_\_\_

DEPTH: 2 FT. 6 IN. LOCATION

"A" P/S READING P TOTAL ANODES 1# 17#0 L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY