

LOCATION 400 Cox Rd (PSNC) Maint Bldg CITY GASTONIA  
BETWEEN Driveway to PSNC STREET & Driveway to PSNC STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	107'	8/1/95		
MAIN TO PROP. LINE	3/4"		107'			
PROP. LINE TO BLDG.	3/4"		107'			

ENTERS: Maint Bldg

BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION N Side of PSNC


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1962

DEPTH: 2 Ft. 6 In. LOCATION East side of Driveway

"A" P/S READING 1.50 TOTAL ANODES 1# 6 17# 0 L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY