

LOCATION 631 Cox Rd. CITY Castroville

BETWEEN Aberdeen BW STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>156'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>0'</u>			<u>9-15-98</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>156'</u>			

ENTERS: 631 BRANCHED INTO: 0

TAP SIZE: 3/4 S PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY CP

MAIN-SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 2 FT. 0 IN. LOCATION

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.125</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY