

LOCATION 811 Cox Rd Sylvan Learning Center CITY Gastonia  
BETWEEN Aden STREET & Cox Dr. - Court Dr STREET


|                     | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG.       | 3/4  | P    | 252    | 2-17-94   |         |         |
| MAIN TO PROP. LINE  | 3/4  | P    | 74'    |           |         |         |
| PROP. LINE TO BLDG. | 3/4  | P    | 178'   |           |         |         |

ENTERS: 811 BRANCHED INTO: 0  
TAP SIZE: 3/8 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION E-Side of 811

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BC  
MAIN-SIZE 12" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1988  
DEPTH: 13 Ft. 1 In. LOCATION 36' W of C of Cox Rd

"A" P/S READING 1.4 TOTAL ANODES 1\* - 17\* - L.R. # \_\_\_\_\_

REMARKS:



| Test Station                               |      |       |
|--|------|-------|
| Reading & Location                         | Lead | Volts |
| P/S Pipeline Lead - Red<br>New Service     | S    | P     |
| P/S Pipeline Lead - White<br>Existing Main | E    |       |

ENG. DEPT. USE ONLY