

LOCATION 5020 Crane Woods Dr. CITY Caston, TN
BETWEEN Summerville Ave. STREET & S. New Hope Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	72'	1-18-01		
MAIN TO PROP LINE	3/4"	P	10'			
PROP LINE TO BLDG	3/4"	P	63'			

ENTERS 5020 BRANCHED INTO

TAP SIZE 3/4" PRESSURE _____ PSI _____ INCHES W C LOCATION 295' E. of center of Summerville Ave.


PRESSURE TEST @ 100 PSI FOR 14 HRS BY S.H.

MAIN-SIZE 4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2020

DEPTH 3 FT 0 IN LOCATION 17' N. of center of Crane Woods Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 11560

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	