

LOCATION 5041 Cramer Woods DR. CITY CASTLETON
BETWEEN Featherstone DR. STREET & Summerfield Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>106'</u>	<u>6-11-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>66'</u>			

ENTERS 5041 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION E of center of Featherstone CT


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. O.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION N of center of Cramer Woods DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 452073

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	