

LOCATION 5064 Cramer Woods Dr CITY Grastonia
BETWEEN Featherstone Ct. STREET & Old Town Ln. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>ID</u>	<u>76'</u>	<u>4-20-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>66'</u>	<u>"</u>		

ENTERS 5064 Cramer Woods Dr BRANCHED INTO ID
TAP SIZE 1/2" PRESSURE 100 PSI INCHES W C LOCATION 76' north


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody of center of Old Town Ln.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3' FT 0" IN LOCATION 19' west of center of Cramer Woods Dr

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 0314580

REMARKS new 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>