

LOCATION 5079 Cramer Woods Dr. CITY Gastonia
BETWEEN old Town Ln. STREET & Featherstone Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>D</u>	<u>108'</u>	<u>8-01-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>38'</u>	<u>1"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>D</u>	<u>70'</u>	<u>1"</u>		

ENTERS 5079 BRANCHED INTO 0
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 294' south


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody
center of old Town Ln.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC C YEAR INSTALLED 2000

DEPTH 3' FT 0" IN LOCATION 17' West of center of Cramer Woods Dr.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 00312524

REMARKS new 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>new</u>