

LOCATION 5091 Cramer Woods DR CITY GASTON, NC

BETWEEN OLD TOWN LN. STREET & Cal-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	89'	6-11-01		
MAIN TO PROP LINE	3/4"	P	8'			
PROP LINE TO BLDG	3/4"	P	81'			

ENTERS 5091 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 5' S. of center of Cramer Woods DR


PRESSURE TEST @ 100 PSI FOR 4 HRS BY SK

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION 537' W. of center of Old Town Ln

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 452023

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	