

LOCATION 5055 Crawford Rd CITY Castroville

BETWEEN Hwy 321 S. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	518'	P	112'	5-21-02		
MAIN TO PROP LINE	90'	P	15'			
PROP LINE TO BLDG	90'	P	97'			

ENTERS 5055 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 1348' W. of center of Hwy 321

PRESSURE TEST @ 100 PSI FOR 1 1/2 HRS BY SKH

MAIN-SIZE 8" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1966

DEPTH 3 FT 0 IN LOCATION 12' S. of center of Crawford Rd

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 LR # 128858

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

