

LOCATION 4204 Creek Ridge Dr. CITY Gastonia
BETWEEN Linsbury Cr STREET & Hickory Hollow Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	31'	7-23-06		
MAIN TO PROP LINE	3/4"	P	10'			
PROP LINE TO BLDG	3/4"	P	21'			

ENTERS 4204 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 600 PSI _____ INCHES W.C. LOCATION 87' N. of center of Creek Ridge Dr


PRESSURE TEST @ 100 PSI FOR 1 1/2 HRS BY S-CH

MAIN SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2001

DEPTH 2 FT 0 IN LOCATION 147' SE of center of Linsbury Cr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 575865

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	