


LOCATION 4201 Creek Ridge Dr CITY GASTONIA
 BETWEEN Linsburg CT STREET & Hollow Pine Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>60'</u>	<u>1-29-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>8'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>52'</u>			

 ENTERS 4201 BRANCHED INTO
 TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 118' W. of center of Hollow Pine Dr
 PRESSURE TEST @ 100 PSI FOR 64 HRS BY S.H.
 MAIN-SIZE 4" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 2000
 DEPTH 3 FT 0 IN LOCATION 17' S. of center of Creek Ridge Dr
 "A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 59885

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	