

LOCATION 4252 Creek Ridge Dr CITY GASTONIA

BETWEEN Timberwood Ct STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>578"</u>	<u>P</u>	<u>130'</u>	<u>2-5-02</u>		
MAIN TO PROP LINE	<u>578"</u>	<u>P</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>578"</u>	<u>P</u>	<u>85'</u>			

ENTERS 4252 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 368' W. of center of Timberwood Ct


PRESSURE TEST @ 100 PSI FOR 14 HRS BY SLH

MAIN-SIZE 4" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 2001

DEPTH 3 FT 0 IN LOCATION 21' S. of center of Creek Ridge Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 20282

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	