

LOCATION 4260 Creek Ridge Dr CITY Castonia
BETWEEN Timberwood Ct STREET & _____ STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	127'	2-5-02		
MAIN TO PROP LINE	5/8"	P	45'			
PROP LINE TO BLDG	5/8"	P	80'			

ENTERS 4260 BRANCHED INTO _____
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 366' W. of center of Timberwood Ct

PRESSURE TEST @ 100 PSI FOR 14 HRS BY S.d
MAIN SIZE 4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2001
DEPTH 3 FT 0 IN LOCATION 21' S. of center of Creek Ridge Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 22287

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	