

LOCATION 4398 Creek Ridge Dr CITY Caston, Va

BETWEEN Huntington Forest Dr STREET & \_\_\_\_\_ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>120'</u>	<u>10-4-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>82'</u>			

ENTERS 4398 BRANCHED INTO \_\_\_\_\_

TAP SIZE 1/2 PRESSURE 600 PSI \_\_\_\_\_ INCHES W C LOCATION 138' N. of center of Huntington Forest Dr.


PRESSURE TEST @ 900 PSI FOR 1/4 HRS BY Silk

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1987

DEPTH 3 FT 0 IN LOCATION 17' SW of center of Creek Ridge Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 905553

REMARKS \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	