

LOCATION 1207 Crescent AveCITY GASTONIABETWEENS 321STREET & Dale

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLastic</u>	<u>115'</u>	<u>2-21-98</u>	<u>2-21-98</u>	<u>115' PLastic</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLastic</u>	<u>107</u>		<u>3/4"-110'</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLastic</u>	<u>8'</u>			

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 322 South of
Date


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By R Hayes

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 Ft. _____ In. LOCATION 17' West of center of Crescent

"A" P/S READING P. TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY