

LOCATION 1220 CRESCENT LN.CITY GASTONIA

BETWEEN

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C+W</u>	<u>115'</u>			
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE:

PRESSURE

P.S.I.

INCHES W.C.

LOCATION

PRESSURE TEST: @ _____ psi For _____ Hrs. By _____

MAIN-SIZE

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

DEPTH:

Ft.


In.

LOCATION

"A" P/S READING

.850TOTAL ANODES 1*ONE 17*

L.R. #

REMARKS: ONE POUND ANODE INSTALLED ON ISOLATED 3/4 C+W SERVICE
TO BRING UP TO CATHODIC PROTECTION

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY