

LOCATION 2410 Crescent Ln CITY Gastonia
BETWEEN Digh St STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>92'</u>	<u>6/14/95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>82</u>			

ENTERS: 2410 BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 P.S.I. INCHES W.C. LOCATION East side of 2410

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT
MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1961
DEPTH: 2 Ft. 6 In. LOCATION North side of Crescent Ln

"A" P/S READING 1.20 TOTAL ANODES 1* 10 17* 0 L.R. # 266245

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY