

LOCATION 706 CRESTWOOD AVE. CITY EAST.  
BETWEEN TANGLEWOOD DR. STREET & FOREST DR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>19'</u>			<u>2-5-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>1'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>18'</u>			

ENTERS: SAME BRANCHED INTO: 700 CRESTWOOD AVE.  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 100' FROM @ OF


TANGLEWOOD DR.  
PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY AM

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION south side of Crestwood Ave.

"A" P/S READING P. TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>		
	P/S Pipeline Lead - White Existing Main	<u>E</u>		