

LOCATION 718 CRESTWOOD AVE. CITY EAST.

BETWEEN Tanglewood Dr. STREET & FOREST DR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>47'</u>		<u>2-7-52</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>25'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>22'</u>			

ENTERS: SAME BRANCHED INTO: 712 CRESTWOOD AVE.

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 227' From @ of

Tanglewood Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY AWT

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY