

LOCATION 712 CRESTWOOD AVE. CITY EAST.

BETWEEN \_\_\_\_\_ STREET & \_\_\_\_\_ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P.</u>	<u>126'</u>			<u>2-7-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>32'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>94'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 228' From (P) OF

Tanglewood Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY A-111

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION Southside of CRESTWOOD AVE.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<b>S</b>		
	P/S Pipeline Lead - White Existing Main	<b>E</b>		