

LOCATION 726 Crestwood Ave. CITY Cast.

BETWEEN Tanglewood Dr. STREET & Forest Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>125'</u>			<u>2-7-97</u>
MAIN TO PROP. LINE	<u>..</u>	<u>"</u>	<u>38'</u>			
PROP. LINE TO BLDG.	<u>..</u>	<u>"</u>	<u>87'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 407' from @ of Tanglewood Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DWA

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN LOCATION South side of Crestwood Ave.

"A" P/S READING P. TOTAL ANODES 1# - 17# - I.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY