

LOCATION 738 CRESTWOOD AVE. CITY EAST.

BETWEEN Forest Dr. STREET & Tanglewood Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>158'</u>			<u>2-11-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>38'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>130'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 334' From @ of

FOREST DR.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DMJ

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION South side of Crestwood Ave.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY