

LOCATION 741 CRESTWOOD AVE CITY EAST.

BETWEEN FOREST DR. STREET & TANGLEWOOD DR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>40'</u>		<u>2-12-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>32'</u>			

ENTERS: SAME BRANCHED INTO: 739 CRESTWOOD AVE.

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 260' From @ OF

FOREST DR.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY AN/

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN. LOCATION Southside of Crestwood Ave.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY